

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

WIN-1589

Effective Date: May 1, 2012

Reevaluation Date: **October 2015**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.

Aluminum Clad Wood Segmented Single Hung Windows, Non-impact Resistant, manufactured by

Lincoln Wood Products, Inc.
1400 W. Taylor Street
Merrill, Wisconsin 54452
Telephone: (715) 536-2461

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Aluminum Clad Wood Segmented Single Hung Window; (O/X)	H-LC30 45 x 81	+30/-30

Product Dimensions:

System	Overall Size	Bottom Sash Size	Fixed Daylight Opening Size
1	45 $\frac{3}{8}$ " x 80 $\frac{1}{2}$ "	42 $\frac{1}{2}$ " x 39 $\frac{3}{4}$ "	39 $\frac{1}{4}$ " x 35 $\frac{1}{4}$ "

Product Identification (Certification Agency Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	LN-1
	Product Name	Clad Double Hung
	Test Standards	AAMA/NWWDA 101/I.S.2-97

Impact Resistance:

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

Installation:

System		
1	Type of Installation	New Construction – Nailing Flange
	Wall Framing	Spruce-Pine-Fir
	Fasteners	Minimum 2" long smooth shank, 12 gauge roofing nails
	Fastener Location/Spacing	Approximately 8 inches from each corner and approximately 8 inches on center along the perimeter of the window
	Fastener Penetration	Minimum of 1 ½ inches into the wall framing members

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC) and the International Building Code (IBC) and the Texas Revisions.